

# Retail Gasoline Outlets



This Fact Sheet provides Best Management Practices (BMPs) that are recommended for facilities that provide vehicle fueling services.

## POTENTIAL POLLUTANT SOURCES

The following activities are potential sources of pollutants:

- ▶ Fueling
- ▶ Air/water supplying areas
- ▶ Dumpster and trash can areas

Pollutants may include:

- ▶ Heavy metals (copper, lead, nickel, and zinc)
- ▶ Hydrocarbons (oil and grease, PAHs)
- ▶ Toxic chemicals (benzene, toluene, xylene)
- ▶ Trash

## Pollution Prevention

Using pollution prevention measures may reduce or eliminate the need for other more costly or complicated procedures.

The following pollution prevention principles apply to most facilities:

- ▶ Use alternative, safer, non-toxic, and/or recycled products.
- ▶ Reduce storm water flow across the site and redirect flows away from storm drains, gutters, and streets.
- ▶ Reduce the use of water and/or use dry methods (i.e., sweeping).
- ▶ Provide ongoing employee training.

## BEST MANAGEMENT PRACTICES AND PROCEDURES

### General

- ▶ Use only dry cleaning method to clean outdoor areas. Do not wash floors or adjacent areas. Never discharge wash water into storm drains, gutters or streets.
- ▶ A permit is required to dispose of anything into the sanitary sewer. Call the City of Stockton Environmental Control Officer at 937-8740 for disposal approval prior to discharging anything into any sanitary sewer drain.
- ▶ Maintain facility and move/cover activities/materials to prevent contact with storm water.
- ▶ Inspect and clean leaks and drips routinely. Only use dry clean method to clean up leaks and spills.
- ▶ Label drains within the facility boundary to indicate whether they flow to an oil/water separator, directly to the sewer, or to a storm drain.
- ▶ Inspect/clean, storm drain inlets within the facility boundary before October 1 each year.



### **Fueling**

- ▶ Maintain fuel dispensing areas using dry cleanup methods such as sweeping for removal of litter and debris, or use of rags and absorbents for leaks and spills.
- ▶ Fueling areas should never be washed down unless the wash water is collected and contained. A permit is required to discharge waste water in the sanitary sewer. Do not discharge waste to the sanitary sewer until contacting the local sewer authority (call the City of Stockton, Environmental Control Office at 937-8740 for disposal approval) to determine if pretreatment is required.
- ▶ Fit fuel dispensing nozzles with “hold-open latches” (automatic shutoffs) except where prohibited by local fire departments.
- ▶ Cover the fuel dispensing area such that the cover’s minimum dimensions are equal to or greater than the area within the grade break or fuel dispensing area. Position roof downspouts to direct water away from fueling areas.
- ▶ Construct berms around the perimeter of the fuel dispensing area to prevent the run-on of uncontaminated storm water from adjacent areas as well as storm water runoff.
- ▶ Slope the pavement near the fuel dispensing areas to prevent ponding.
- ▶ Post signs at the fuel dispenser or fuel island warning vehicle owners/operators against “topping off” of vehicle fuel tanks.
- ▶ Install protective guards around tanks and piping to prevent vehicle damage and spills.

### **Dumpster and Trash Can Areas**

- ▶ Minimize the possibility of storm water pollution from outside waste receptacles by doing the following:
  - ❖ Use only water-tight waste receptacle(s) and keep the lid(s) closed.
  - ❖ Grade and pave the waste receptacle area to prevent run-on of storm water.
  - ❖ Install a roof over the waste receptacle area;
  - ❖ Install low-containment berms around the waste receptacle area.
  - ❖ Empty waste receptacles frequently.

### **Spill Cleanup**

- ▶ Develop and maintain a spill response plan.
- ▶ Place an adequate stockpile of spill cleanup materials where it will be readily available.
- ▶ Spot clean leaks and drips routinely. Use absorbent to remove leaks and drips. Dispose of absorbent properly.
- ▶ Clean leaks, drips, and other spills with as little water as possible. Use rags for small spills, a damp mop for general cleanup, and dry absorbent material for larger spills.
- ▶ Keep the spill from entering streets, gutters, or storm drains.

### **EMPLOYEE TRAINING**

- ▶ Train employees on these practices.
- ▶ Train staff on the proper maintenance of your facility.
- ▶ Train employees on your facility’s spill control plan and spill containment/cleanup procedures.
- ▶ Establish a regular training schedule for all employees, and conduct annual refresher training.
- ▶ Use a training log or similar method to document training.

**City of Stockton 937-8700**

***Water that goes into storm drains doesn’t go to the sewer plant to be treated, but flows directly into our rivers, creeks, sloughs, and the Delta. Remember: Only Rain Down the Storm Drain!***